



Addendum No. 1

October 9, 2019

For The Contract Documents For The

2019 Superblock Pedestrian Improvements (Phase I) CIP-02-19

NOTICE TO ALL PLAN HOLDERS:

You are hereby notified of the following clarifications, additions, and/or revisions to the contract documents for the above referenced project:

SECTION 3: BID SCHEDULE

1. Correct Bid Date at top of Schedule of Values Form, p.25, from "*October 22, 2019*" to "*October 15, 2019*". October 15, 2019, is the correct bid date of the project.

SECTION 8: STANDARD SPECIFICATIONS & SPECIAL PROVISIONS

2. Add the following sentence to the end of the modifications to **Section 03010.40 – Vinyl Clad Fabric**: "*Vinyl clad chain link fence fabric shall be 9 gauge.*"

SECTION 9: PLANS, DRAWINGS AND EXHIBITS

3. Plansheet C7, Detail B SE 132ND AVENUE - SECTION: Modify Note reading " 6" Post w/42" Exposure Place 8 @ 8' OC " to read "*2-3/8" Post w/42" Exposure Place 8 @ 8' OC*".
4. Plansheet G2, Sheet Index: Modify General Sheets G3 Title from "General Notes" to "Erosion Control Notes".

16000 SE Misty Drive
Happy Valley, Oregon 97086-4288
Telephone: (503) 783-3800 Fax: (503) 658-5174
Website: www.ci.happy-valley.or.us

5. Plansheet C7, Sheet Title: Modify Title from "SE Ridgecrest Rd Retaining Wall Plan and Profile Sta 17+38 - 18+04" to "Retaining Wall & Fence Plan & Profile Sta 17+38 - 18+04".

Carol Earle, P.E., City Engineer

Contractors Acknowledgement of Addendum No. 1:

Contractor Signature

Date

16000 SE Misty Drive
Happy Valley, Oregon 97086-4288
Telephone: (503) 783-3800 Fax: (503) 658-5174
Website: www.ci.happy-valley.or.us

Preserving and enhancing the safety, livability and character of our community